AG90-SERIES ELECTROMAGNETIC INSERTION FLOW METER





APPLICATIONS

Irrigation
Agricultural automation
Reuse/Reclaim water
Surface water
Fertigation/Chemigation
Well usage monitoring
Propeller meter replacement

Features

- Direct replacement for propeller meter
- No moving parts to rebuild
- · Less pipe obstruction
- Durable
- Easy to install
- No routine maintenance
- Pulse Output Standard
- 4 year battery life

The **AG90-series** battery powered, insertion electromagnetic flow meter is designed for use with conductive fluids in 4"–12" pipe. The AG90's stainless steel body allows the meter to operate in a wide range of temperatures, pressure, and corrosive or dirty environments.

The AG90 is highly suitable for difficult applications. With no moving parts, over-run conditions will not degrade the life of the AG90. It is resistant to wear from debris found in surface or ground water and there are no bearings to wear out or propellers to damage.

Rate and total units can be set via the front panel touch key pad by the user. Bidirectional flow is standard with totals available in forward, reverse, net, batch forward and batch reverse.

The AG90 is battery powered and an output cable is available for transmitting the pulse signal to remote devices. The AG90 includes a Seametrics saddle which has been designed to accommodate a wide range of pipe sizes and types while ensuring correct placement in the pipe. In addition, an optional internal data logger allows local storage of flow history.

Contact Your Supplier





Free battery replacement at year four with warranty registration!

253.872.0284 seametrics.com




Specifications*

Pipe Size		4" to 12"					
Materials Sensor Body		316 SS					
Materials	Electrodes	Hastelloy					
	Housing	Powder-coated diecast aluminum					
	Electrode Cap	PVDF (Kynar®)					
	O-Ring	EPDM					
Temperature	Operating	10° to 140° F (-12° to 60° C)					
remperature	Storage	-40° to 158° F (-40° to 70° C)					
	Fluid Temp.	32° to 200° F (0° to 93° C)					
Pressure		200 psi (14 bar)					
Flow Rate		0.5 - 4.5 m/sec (1.64 - 14.8 ft/sec) (Low flow cutoff .15 m/sec; .49 ft/sec)					
Calibration Accuracy	0.5 - 4.5 m/s (1.64-14.76 ft/sec)	+/- 2% of reading					
	0.3 - 0.5 m/sec (0.98 - 1.64 ft/sec)	+/- (2% of reading + 0.25% of full scale)					
Display	Туре	128x64 dot-matrix LCD					
	Digits	5 Digit Rate		8 Digit Total			
	Units	Rate Volume Units	Rate Time Units	Total Volume Units			
	Please Note: All meters are factory set for gallons per minute (GPM) rate and acre foot total. If other units are required, they can be set in the field.	Gallons Liters Barrels (42 gallons) Cubic Feet Cubic Meters Million Gallons¹ Mega Liters¹ Imperial Gallons Million Imperial Gallons¹	Second Minute Hour Day	Gallons Gallons x 10 Gallons x 100 Gallons x 1000 Million Gallons Liters Kilo Liters Mega Liters Barrels (42 gallons) Cubic Meters	Cubic Meters x 1000 Cubic Feet Cubic Feet x 1000 Million Cubic Feet Imperial Gallons Imperial Gallons x 1000 Million Imperial Gallons Acre Inch Acre Foot Fluid Ounce		
	Bidirectional	Forward Total, Reverse Total, Net Total, Batch Forward, Batch Reverse					
Power		One lithium 7.2V 'D' size battery pack, replaceable.					
Scaled Pulse	Signal	Current sinking pulse, isolated, 36 Vdc at 10 mA max					
Output	Pulse Rates	User-scalable from 0.1 to 99,999.9 volume units/pulse. Pulse width varies with output frequency, 150 pulses/sec max					
Cable	Optional Output Cable	20ft (6m) standard length polyurethane jacketed cable—for power and outputs. (Lengths up to 200' (60 m) available.)					
Conductivity		>20 microSiemens/cm					
Empty Pipe Detection		Hardware/software, conductivity-based					
Regulatory		C € (EN 61326) Pending					
Environmental		IP67					

^{*} Specifications subject to change. Please consult our website for the most current data (seametrics.com).

Flow Range*

Nominal Pipe Size	4"	6"	8"	10"	12"
Low Flow Cutoff GPM	19.3	43.11 2.72	77.1	120.5	173.5
Low Flow Cutoff LPS	1.22		4.86	7.6	10.95
Min GPM	64.3	144.6	257	401.6	578.3
Min LPS	4.1	9.1	16.2	25.3	36.5
Max GPM	578	1301	2313	3614	5204 328.3
Max LPS	36.5	82.1	145.9	228	




Upstream straight pipe is selected during initial setup. Upstream options are 5X or 10X the diameter and are based on the amount of straight pipe available in either new or propeller meter replacement installation. Downstream straight pipe requirement is 2X the diameter. See programming setup for details.

253.872.0284 seametrics.com

¹ Rate Time Unit is available in Day only. Kynar is a registered trademark of Arkema, Inc.





Features



Quickly and easily change Total Volume Units, Flow Rate Units, Pulse Output Scaling, and many other settings using the two light sensor button controls on the display panel.

Dimensions





Each saddle has a range of actual pipe size O.D. that it will work with. When you order your meter, you will specify the nominal pipe size and the saddle provided will work with the following actual pipe O.D.


Saddle Size	Range	
4"	4.00"- 4.90"	
6"	6.00"- 6.90"	
8"	8.00" - 9.05"	
10"	10.00" - 11.10"	
12"	12.10" - 13.20"	

Consult factory if your OD does not match.

253.872.0284 seametrics.com



How to Order Worksheet



	(1)	(2)	(3)	(4)	(5)
	Size	Power	Optional Output (Comes standard with one pulse output)	Options	Power/Output Cable (Must select one)
-0)400 4"	-BX	-X (requires cable for pulse output)	-XX None	-0000 No Cable (Battery only, no output)
-0	0600 6"			-01 Data Logger	-0064 6 meter (20 ft)
-0	0800 8"				-0154 15 meter (50 ft)
-1	000 10"				-0304 30 meter (100 ft)
-1	200 12"				-0454 45 meter (150 ft)
					-0604 60 meter (200 ft)

Note: All meters are factory set for gallons per minute (GPM) rate and acre foot total. If other units are required, they can be programmed in the field.

Note2: Saddle included with meter

Note3: The AG90 can be externally powered by connecting DC power with the power/output cable. Batteries then serve as backup power.

For chemical or fertilizer injection applications, the injection point must be placed downstream of the meter or far enough upstream for complete mixing to occur before the flow reaches the meter. (See fertigation technical bulletin on Seametrics website, seametrics.com.)

User is responsible for reviewing end use application with their supplier for product suitability.



